



Certificate No. : T-0071

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33




Fax : +91 (0265) 2638382 Web : www.erda.org

E-mail : erda@erda.org, dir@erda.org



TEST REPORT

SHEET 1 OF 7

NAME & ADDRESS OF CUSTOMER RAVINDRA ENGINEERING CORPORATION SHED NO. 6, NANGARGAON IND. ESTATE, LONAVLA 410401 DIST : PUNE TAL : MAVAL	REPORT No. PLV/10/SC/972 DATE: 03.11.2008	
	CUSTOMER REF.NO. NIL	DATED: 16.09.2008
	DATE OF SAMPLE RECEIPT: 14.10.2008	DATE OF TESTING: 16.10.2008 to 19.10.2008
	SAMPLE DESCRIPTION CURRENT TRANSFORMER Rated voltage: 660 V, Ratio: 1000/5A Burden: 7.5 VA, No. of Cores : One Frequency: 50 Hz. Rated Insulation Level: 3 kVrms, Class: 0.5 Rated short time current & its duration: 65kArms for 1 sec. with 162.5 kApeak. Further details as per sheet No. 3 OF 7	
SAMPLE IDENTIFICATION ERDA IDENTIFICATION NO.: LSC-02-165/01 TYPE: BAR PRIMARY(BPL) SERIAL No.: R1/01 DRAWING NO.: BPL 01		
TEST DETAILS Short time current test ENCLOSURES: NUMBER OF OSCILLOGRAM : ONE NUMBER OF TEST CIRCUIT DIAGRAM : ONE NUMBER OF DRAWINGS : ONE TEST WITNESSED BY: Mr. SANJAY MALI	TEST SPECIFICATION IS: 2705 – 1992	
REMARKS: The sample conforms to the requirement of standard for short time current test.		
 PREPARED BY	 CHECKED BY	 APPROVED BY

- NOTE: 1. This report relates only to the particular sample received for testing in good condition at ERDA.
 2. This report cannot be reproduced in part under any circumstances.
 3. Publication of this report requires prior permission in writing from Director, ERDA.
 4. Only test asked for by party have been carried out.

TE0059623

