



Certificate No. : T-0071

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382 Web : www.erda.org

E-mail : erda@erda.org, dir@erda.org



## TEST REPORT

SHEET 1 OF 7

<b>NAME &amp; ADDRESS OF CUSTOMER</b>  <b>M/s. RAVINDRA ENGINEERING CORPORATION</b> PLOT NO. 6, LONAVALA INDUSTRIAL CO-OPERATIVE ESTATE LIMITED, NANGARGAON, LONAVALA-410 401 MAHARASHTRA. INDIA	<b>REPORT NO:</b> PLV/10/SC/933 <b>DATE:</b> 21.10.2008	
	<b>CUSTOMER REF.NO:</b> NIL	<b>DATED:</b> 16.09.2008
	<b>DATE OF SAMPLE RECEIPT:</b> 29.09.2008	<b>DATE OF TESTING:</b> 04.10.2008 to 11.10.2008
	<b>SAMPLE DESCRIPTION</b>  <b>CURRENT TRANSFORMER</b> Rated voltage: 660 V, No. of cores : One, Freq.: 50 Hz, Ratio of CT: 40/5 A, Class: 0.5, Burden: 7.5 VA Rated Insulation Level: 3 kVrms, Rated short time current & its duration: 2 kArms for 1 sec. with 5 kA peak  Further details as per sheet No. 3 of 7	
<b>SAMPLE IDENTIFICATION</b>  <b>ERDA ID NO:</b> LSCLWO 0064767/01  <b>SERIAL NO:</b> R2/01  <b>DRAWING NO:</b> WPL 01  <b>TYPE :</b> WOUND PRIMARY(WPL)		
<b>TEST DETAILS</b> Short time current test (Cl. No. 9.6) <b>ENCLOSURES:</b> NUMBER OF OSCILLOGRAMS : TWO NUMBER OF PHOTOGRAPH : ONE NUMBER OF TEST CIRCUIT DIAGRAM : ONE NUMBER OF DRAWINGS : ONE <b>REMARKS:</b> The sample <b>conforms</b> to the requirement of short time current test as per standard.	<b>TEST SPECIFICATIONS</b> IS: 2705 (Part 1 & 2) – 1992	
<b>PREPARED BY</b> <i>P. K.</i>	<b>CHECKED BY</b> <i>P. K.</i>	<b>APPROVED BY</b> <i>[Signature]</i>

- NOTE:
1. This report relates only to the particular sample received for testing at ERDA.
  2. This report cannot be reproduced in part under any circumstances.
  3. Publication of this report requires prior permission in writing from Director, ERDA.
  4. Only test asked for by customer have been carried out.

TE 0075547

